



- PRODUCT TO BE MANUFACTURED IN ACCORDANCE WITH CSA A23.4
- MINIMUM CONCRETE STRENGTH AT 28 DAYS: 32 MPA
- REINFORCED WITH GRADE 400 REBAR

FRASERWAY PRECAST LTD			
WWW.FRASERWAYPRECAST.COM		604-534-2911	
ANCHOR BLOCK (24" PIPE SADDLE)			
250mm DR11 HDPE WATERMAIN			
SIZE	DRAWING #	13167	REV
A	AB 610x300x365		B
			SHEET
			1/1